



# Certificate of Compliance

**Certificate:** 2761992

**Master Contract:** 252040

**Project:** 2761992

**Date Issued:** October 31, 2014

**Issued to:** Lovato Electric S.p.A.  
Componenti Elettrici per  
Automazioni Industriali  
Via Don E Mazza 12  
Gorle, Bergamo 24020  
Italy

**Attention:** Raffaele Ferrari

*The products listed below are eligible to bear the CSA Mark shown  
with adjacent indicator ▲*



*Kim Atkins*

**Issued by:** K. Atkins

## **PRODUCTS**

CLASS 3211 37 INDUSTRIAL CONTROL EQUIPMENT - Sub-Assemblies

Fuseholders, 1 or 2 pole, with or without blown fuse indicator, for use with Supplemental Type Fuses (10 x 38mm), IR-30kA:

|            |   |
|------------|---|
| FB01 D 1P  | 1 pole, 30A-1000V fuseholder for Supplemental Type Fuses                |
| FB01 D 1PL | 1 pole, 30A-1000V fuseholder for Supplemental Type Fuses with indicator |
| FB01 D 2P  | 2 pole, 30A-1000V fuseholder for Supplemental Type Fuses                |
| FB01 D 2PL | 2 pole, 30A-1000V fuseholder for Supplemental Type Fuses with indicator |



**Certificate:** 2761992  
**Project:** 2761992

**Master Contract:** 252040  
**Date Issued:** October 31, 2014

Fuseholder Assemblies, with or without Blown Fuse Indicator, DIN Rail Mounted, 1 to 4 pole, 30A, 750V, intended for use with Supplemental Fuses 10x38 mm. Part No's are as follows:

| Model\Cat No. | Ratings<br>Amperes | Volts   | Withstand rating | No. of Poles      | Indicator      |
|---------------|--------------------|---------|------------------|-------------------|----------------|
| FB01 F 1P     | 30A                | 750 VAC | 200kA rms sym    | 1 pole            | no             |
| FB01 F 0N     | 30A                | 750 VAC | 200kA rms sym    | neutral           | no             |
| FB01 F 1N     | 30A                | 750 VAC | 200kA rms sym    | 1 pole + neutral  | no             |
| FB01 F 2P     | 30A                | 750 VAC | 200kA rms sym    | 2 poles           | no             |
| FB01 F3P      | 30A                | 750 VAC | 200 kA rms sym   | 3 poles           | no             |
| FB01 F 3N     | 30A                | 750 VAC | 200 kA rms sym   | 3 poles + neutral | no             |
| FB01 F 4P     | 30A                | 750 VAC | 200 kA rms sym   | 4 poles           | no             |
| FB01 F 1PL    | 30A                | 750 VAC | 200 kA rms sym   | 1 pole            | with indicator |
| FB01 F 1NL    | 30A                | 750 VAC | 200 kA rms sym   | 1 pole + neutral  | with indicator |
| FB01 F 2PL    | 30A                | 750 VAC | 200 kA rms sym   | 2 poles           | with indicator |
| FB01 F 3PL    | 30A                | 750 VAC | 200 kA rms sym   | 3 poles           | with indicator |
| FB01 F 3NL    | 30A                | 750 VAC | 200 kA rms sym   | 3 poles + neutral | with indicator |
| FB01 F 4PL    | 30A                | 750 VAC | 200 kA rms sym   | 4 poles           | with indicator |

Notes:

1. For assembly in equipment where the acceptability is evaluated by CSA and or the local inspection authority.
2. Not for interrupting current.
3. Fuseholders must be installed in an enclosure or other means must be provided for strain relief on the conductors to the wiring terminals restricting the movement of the conductors and transmission of strain to the termination.

**APPLICABLE REQUIREMENTS**

|                                  |   |  |
|----------------------------------|---|--|
| CAN/CSA-C22.2 No. 0-10           | - | General Requirements - Canadian Electrical Code, Part II |
| CSA Standard C22.2 No. 4248.1-07 | - | Fuseholders, General Requirements                        |
| CSA Standard C22.2 No. 14-13     | - | Industrial Control Equipment                             |
| *CSA Standard C22.2 No. 39-13    | - | Fuseholder Assemblies                                    |
| CSA Standard C22.2 No. 158-10    | - | Terminal Blocks  |
| * CSA Standard C22.2 No. 65-93   | - | Wire Connectors  |

\* Used as a guide



**Certificate:** 2761992

**Master Contract:** 252040

**Project:** 2761992

**Date Issued:** October 31, 2014

---

## **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The following shall appear on each fuseholder in a permanent manner;

- Company's identification; Name or Tradename
- Complete electrical rating; 30A, 750V ac or 30A, 1000Vdc (as applicable)
- Model or Cat. No.
- CSA Component Acceptance Mark.
- Intended Wire Size/Range and Tightening Torque; #8-18 AWG STRANDED\SOLID, 18 to 22 in-lbs or 2 – 2.5Nm
- “USE CU WIRE ONLY” or the equivalent
- “DO NOT OPEN UNDER LOAD” or “NOT FOR INTERRUPTING CURRENT”, or the equivalent.
- Withstand rating: 200kA rms sym at 750V ac or 30kA dc at 1000V dc (as applicable)