



Type examination certificate

Number **T12526-UK** revision 1

Project number 3562362

Page 1 of 1

Issued by

NMi Certin UK (TIC) Ltd.,
appointed and approved by the Secretary of State to perform tasks with respect
to conformity modules mentioned in regulation 39 of the Measuring
Instruments Regulations 2016 as amended, after having established that the
measuring instrument meets the applicable requirements of the Measuring
Instruments Regulations 2016 as amended, to:

Manufacturer

Lovato Electric S.p.A.
Via Don E. Mazza, 12
Gorle (BG)
Italy

Measuring instrument

A static **Active Electrical Energy Meter**

Type : DMED311MID7
DMED341MID7
DMED341MID7E
DMED341MID7ER

Manufacturer's mark or name : Lovato Electric S.p.A.

Reference voltage : 3x230/400 V

Reference current : 15 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -25 °C / +70 °C

Further properties are described in the annexes:

- Description T12526-UK revision 1;

- Documentation folder T12526-UK-2.

Valid until

21 September 2033

Initially issued

21 September 2023

Remark

This revision replaces the earlier version, including its documentation folder.

Issuing Authority

NMi Certin UK (TIC) Ltd., Approved Body number 8506

2 November 2023

Certification Board

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The appointment of NMi Certin UK (TIC) Ltd., as
Approved Body can be verified at
[https://www.gov.uk/uk-market-conformity-
assessment-bodies](https://www.gov.uk/uk-market-conformity-assessment-bodies)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.



23275



Description

Number **T12526-UK** revision 1
Project number 3562362
Page 1 of 3

1 General information about the instrument

All properties of the static active electrical energy meter, whether mentioned or not, shall not be in conflict with the legislation.

1.1 Essential parts

Description	Document	Remarks
measuring sensor: - CT sensor	12526/0-07, 12526/0-08	Alternative CT sensors: - Malio: 33400096-A 2243 - Hongfa: HDCT406-1
Top Board: A0321B1 - DMED311MID7 - DMED341MID7 - DMED341MID7E - DMED341MID7ER	12526/0-13, 12526/0-15, 12526/0-16 12526/0-14, 12526/0-17, 12526/0-18 12526/1-12, 12526/1-14, 12526/1-15 12526/0-13, 12526/1-16, 12526/1-17	All parts of the printed circuit boards are essential, except the components which are related to parts as described in paragraph 1.4 or 1.6.
Bottom Board: A0321A1 - DMED311MID7	12526/0-19, 12526/0-20, 12526/0-21, 12526/0-22	
Bottom Board: A0321D0 - DMED341MID7 - DMED341MID7E - DMED341MID7ER	12526/0-23, 12526/0-24, 12526/0-25, 12526/0-26 12526/1-18, 12526/1-19, 12526/1-22, 12526/1-23 12526/1-20, 12526/1-21, 12526/1-24, 12526/1-25	
Display board: A0321B1 - DMED311MID DMED341MID7 - DMED341MID7E - DMED341MID7ER	12526/0-27	

1.2 Essential characteristics

- 1.2.1 See UK-type examination certificate T12526-UK revision 1 and the characteristics mentioned below.
- 1.2.2 Approved meter types : DMED311MID7, DMED341MID7, DMED341MID7E and DMED341MID7ER. An explanation of all type designations are presented in document no. 12526/0-04.
- 1.2.3 Frequency : 50 Hz
- 1.2.4 Meter constant : 2.000 imp./kWh
- 1.2.5 Number of registers : Up to 2 registers
- 1.2.6 Error messages : Errors are indicated with an error symbol (Err). See document no. 12526/0-12.
- 1.2.7 Registration method : The following registration methods are allowed:
measurement of import and export energy by means of summation by sign (sum of import energy per phase and sum of export energy per phase)



Description

Number **T12526-UK** revision 1
Project number 3562362
Page 2 of 3

- 1.2.8 Phase sequence : the meter is not sensitive to the direction of the applied phase sequence.
A specific symbol is stated on the nameplate.
- 1.2.9 Export energy : the meter is capable of measuring energy in 2 directions.
The meter can also be used with 2 phases loaded with import energy and 1 phase loaded with export energy.
- 1.2.10 Software specification (refer to WELMEC 7.2):
 - Software type P;
 - Risk Class C;
 - Extension L, T, I3 while extensions O, D, S and T are not applicable.

Software version	Identification number (checksum)	Remarks
00	CSH3DF1 CSL20EE	DMED311MID7
00	CSHBE38 CSL4FC9	DMED341MID7
00	CSH B53D CSL B300	DMED341MID7E
00	CSH D3AC CSL 533C	DMED341MID7ER

The software version (Obis code: 96,90,2) is displayed in the display sequence.

1.3 Essential shapes

- 1.3.1 The nameplate is bearing at least, good legible, information as mentioned in the regulations on energy meters. An example of the markings is shown in document no. 12526/0-05, 12526/0-06, 12526/1-05, 12526/1-06, 12526/1-07, 12526/1-08, 12526/1-09 and 12526/1-10.
- 1.3.2 Sealing: see chapter 2.
- 1.3.3 1.3.3 The registration observation is executed by means of a LED.

1.4 Conditional parts

- 1.4.1 Terminal block
The connections for the current cables on the terminal block have a diameter of at least 7 mm. The cables are connected with the terminal block via 1 screw. See documents no. 12526/0-01, 12526/0-02, 12526/0-03 and 12526/0-09.



Description

Number **T12526-UK** revision 1
Project number 3562362
Page 3 of 3

1.4.2 Housing

The meter has got a dustproof housing, which has sufficient tensile strength. The cover is made of synthetic material. An example of the housing is presented in document no. 12526/0-01, 12526/0-02 and 12526/0-03, 12526/1-01, 12526/1-02, 12526/1-03 and 12526/1-04.

1.4.3 Terminal cover

The terminal cover is made of synthetic material.

1.4.4 Register

The quantity of measured energy is presented by means of a display with at least 6 elements. The way of presentation is described in document no. 12526/0-11. For test purposes an indication with a least significant element of at least 0,01 kWh, can be arranged via loop button icon on the meter.

1.4.5 Tariff control

When the meter (DMED311MID7) is provided with more than one register, a tariff control is available by means of tariff inputs, whereby the EMC-requirements are fulfilled as described in Measuring Instruments Regulations (2016) Schedule 1E.

1.5 Conditional characteristics

1.5.1 Maximum current:

smaller than or equal to 80 A, and at least 5 times higher than the reference current.

1.5.2 Minimum current: 0,75 A

1.6 Non-essential parts

1.6.1 Pulse output

2 Seals

Both screws of the meter cover are sealed.

An example of the sealing is presented in document no. 12526/0-10 and 12526/1-11.

3 Conditions for conformity assessment according to module D or F

The influence factors for temperature, frequency and voltage, which are necessary to perform the conformity assessment according to module D or F, are presented in Annex 1, belonging to this UK-type examination certificate. Based on the WELMEC 11.1, section 2.4.6, the sum of the square values is presented

Influence factors for temperature, frequency and voltage

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The values depicted in the table below present the root sum square values per load point, determined via the following formula:

$$\delta e(T, U, f) = \sqrt{\delta e^2(T, I, \cos\varphi) + \delta e^2(U, I, \cos\varphi) + \delta e^2(f, I, \cos\varphi)}$$

with:

- $\delta e(T, I, \cos\varphi)$ = the additional percentage error due to the variation of the temperature at a certain load;
- $\delta e(U, I, \cos\varphi)$ = the additional percentage error due to the variation of the voltage at the same load;
- $\delta e(f, I, \cos\varphi)$ = the additional percentage error due to the variation of the frequency at the same load.

Current	Power factor	-25°C [%]	-10°C [%]	+5°C [%]	+23°C [%]	+40°C [%]	+55°C [%]	+70°C [%]
Imin	1	0,3	0,2	0,1	0,0	0,1	0,2	0,4
Itr	1	0,3	0,2	0,1	0,0	0,1	0,2	0,4
	0,5 ind.	1,3	0,8	0,5	0,2	0,4	0,4	0,5
	0,8 cap.	1,0	0,6	0,3	0,1	0,3	0,5	0,7
Itr phase R	1	0,2	0,2	0,1	0,0	0,1	0,2	0,3
	0,5 ind.	0,4	0,3	0,2	0,2	0,3	0,3	0,4
Itr phase S	1	0,3	0,2	0,1	0,0	0,1	0,2	0,4
	0,5 ind.	1,4	0,9	0,5	0,2	0,4	0,5	0,6
Itr phase T	1	1,3	0,8	0,4	0,0	0,3	0,4	0,5
	0,5 ind.	1,3	0,8	0,4	0,2	0,3	0,4	0,5
10 ltr	1	0,3	0,2	0,1	0,0	0,1	0,2	0,3
	0,5 ind.	1,3	0,8	0,4	0,2	0,4	0,5	0,6
	0,8 cap.	0,9	0,6	0,3	0,1	0,3	0,5	0,8
10 ltr phase R	1	0,2	0,2	0,1	0,0	0,1	0,2	0,3
	0,5 ind.	0,4	0,3	0,2	0,2	0,2	0,3	0,4
10 ltr phase S	1	0,3	0,2	0,1	0,0	0,1	0,2	0,4
	0,5 ind.	1,4	0,9	0,4	0,2	0,4	0,6	0,7
10 ltr phase T	1	1,3	0,8	0,4	0,0	0,3	0,5	0,5
	0,5 ind.	1,3	0,8	0,4	0,2	0,3	0,5	0,5
Imax	1	0,3	0,2	0,1	0,0	0,1	0,2	0,4
	0,5 ind.	1,4	0,9	0,4	0,2	0,4	0,6	0,6
	0,8 cap.	1,0	0,6	0,3	0,1	0,4	0,6	0,8
Imax phase R	1	0,2	0,2	0,1	0,0	0,1	0,2	0,3
	0,5 ind.	0,4	0,3	0,3	0,3	0,3	0,4	0,5
Imax phase S	1	0,3	0,2	0,1	0,0	0,1	0,2	0,4
	0,5 ind.	1,4	0,9	0,4	0,3	0,4	0,6	0,6
Imax phase T	1	0,0	0,1	0,2	0,0	0,4	0,5	0,8
	0,5 ind.	1,3	0,8	0,4	0,2	0,4	0,5	0,5