




Product designation			Switch disconnector
Product type designation			GA
Number of poles		Nr.	3
Operating voltage type			AC
Contact characteristics			
IEC Conventional free air thermal current Ith		Α	125
Rated insulation voltage Ui IEC/EN		V	1000
Rated impulse withstand voltage Uimp		kV	8
Operating current le			
AC21A			
	400V	Α	125
	500V	Α	125
	690V	Α	125
AC22A			
	400V	Α	125
	500V	Α	125
	690V	Α	125
AC23A			
	400V	Α	125
	500V	Α	100
	690V	Α	47
Power dissipation per pole max		W	6.3
Rated operational power AC23A			
	400V	kW	55
	690V	kW	45
Rated short time current (1s) Icw (rms)		kA	2.5
Conditional short-circuit current (rms)		kA	50
Short-circuit protection with fuse		Class/A	gG125
Making capacity AC23A 400V		A	1250
Breaking capacity AC23A 400V		A	1000
Mechanical life		cycles	30000
Electrical life AC21A		cycles	30000
Mechanical features		Cycles	30000
Operating position			
Operating position	n o rmo ol		Vertical plan
	normal allowable		Vertical plan
·	allowable		Any
Fixing			Screw / DIN rail 35mm
Terminals			
	type		Pillar
	width	mm	12.4
	height	mm	10.4
	screw		M8
	tool		Metric Allen key 4




ENERGY AND AUTOMATION

Tightening torque for terminals			
	min	Nm	5
	max	Nm	6
	min	lbin	45
	max	lbin	54
Conductor section			
	IEC min	mm²	4
	IEC max	mm²	70
	AWG/kcmil min		12
	AWG/kcmil max		1
UL technical data			
UL Standard			UL98
General purpose current rating		Α	100
Operating voltage max		V	600
Horsepower/FLA current three phase motor			
	240V	HP	30/80
	480V	HP	60/77
	600V	HP	60/62
Short circuit rating		kA rms	50 (600V) / 100 (480V)
Short circuit rating with fuse		Class/A	J/100A / CC-J- T/max. 200A
Minimum enclosure dimensions at rated current			
	mm	mm	150x140x110
	in	in	5.9 x 5.5 x 4.3
Ambient conditions			
Operating temperature			
	min	°C	-25
	max	°C	+55
Storage temperature			
	min	°C	-40
	max	°C	+70
Max altitude		m	3000
Resistance & Protection			
Frontal IP degree			IP20
Pollution degree			3
Dimensions			





Wiring diagrams



Certifications and compliance

Compliance

CSA C22.2 n°4

IEC/EN 60947-1

IEC/EN 60947-3

UL98

Certifications

CCC

CSA C22.2 n°4

cULus according to UL98

EAC

ETIM classification

ETIM 8.0

EC000216 -Switch disconnector