



# 中国国家强制性产品认证证书

证书编号：2009010304334317

委托人名称、地址

Lovato Electric S. p. A.  
Via Don E. Mazza, 12-24020 Gorle (Bergamo)-Italy

生产者（制造商）名称、地址

Lovato Electric S. p. A.  
Via Don E. Mazza, 12-24020 Gorle (Bergamo)-Italy

生产企业名称、地址

Lovato Electric S. p. A.  
Via Don E. Mazza, 12-24020 Gorle (Bergamo)-Italy

产品名称和系列、规格、型号

切换电容器接触器

BFK26,BFK32,BFK38(型号解释详见附件);Ui:690V; Ith:30A(BFK26),36A(BFK32),43A(BFK38); Ue/Qe:  
BFK26:AC-6b:AC240V/11kvar,400V/20kvar,440V/22kvar,690V/22kvar;  
BFK32:AC-6b:AC240V/14kvar,400V/25kvar,440V/27.5kvar,690V/30kvar;  
BFK38:AC-6b:AC240V/17kvar,400V/30kvar,440V/33kvar,690V/36kvar;  
Us:AC24V,AC48V,AC110V,AC230V,AC400V 50Hz,3P

产品标准和技术要求

GB/T14048. 4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2017年11月22日 有效期至：2022年11月22日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2009年04月01日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2009010304334317

## NAME AND ADDRESS OF THE APPLICANT

Lovato Electric S.p.A.  
Via Don E. Mazza, 12-24020 Gorle(Bergamo)-Italy

## NAME AND ADDRESS OF THE MANUFACTURER

Lovato Electric S.p.A.  
Via Don E. Mazza, 12-24020 Gorle(Bergamo)-Italy

## NAME AND ADDRESS OF THE FACTORY

Lovato Electric S.p.A.  
Via Don E. Mazza, 12-24020 Gorle(Bergamo)-Italy

## PRODUCT NAME, MODEL AND SPECIFICATION

Contactor for Capacitor Switching

BFK26,BFK32,BFK38;Ui:690V; Ith:30A(BFK26),36A(BFK32),43A(BFK38); Ue/Qe: BFK26:AC-6b:AC240V/11kvar, 400V/20kvar,440V/22kvar,690V/22kvar; BFK32:AC-6b:AC240V/14kvar,400V/25kvar,440V/27.5kvar,690V/30kvar; BFK38:AC-6b:AC240V/17kvar,400V/30kvar,440V/33kvar,690V/36kvar; Us:AC24V,AC48V,AC110V,AC230V,AC400V 50Hz;3P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Nov.22,2017

Valid until: Nov.22,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.01,2009

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE





# 中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2009010304334317

纸号: 1848679

型号的解释:

BFK 26 00 A

I II III IV

- I- Series designation 系列
- II- Device Size 电流等级
- III- Contact configuration - 00 - 3NO (Main)
- IV- Supply coil voltage - A - AC 交流电压线圈

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心